

描	校
---	---

11	DZMS0015.05.030	STRAIGHT TUBE 管	1	WELDMETN 焊接件	263	263	
10		螺栓M16X90BOLT M16X90 螺栓M16X90	40	8.8 CLASS	0.16	6.4	
9	DZMS0015.05.01	CUSHION 垫	1	460#HEAT RESISTANT RUBBER SLAB	1	1	
8	DZMS0015.05.020	PULVERIZED COAL CONVEYING TUBE 输粉管	1	WELDMETN 焊接件	359	359	
7	DZMS0015.05.010	ELBOW 弯管	1	WELDMETN 焊接件	248	248	
6	DZMS0007.06.01	FLANGE 法兰	2	Q235A	41	82	
5		EXPANSION JOINT 膨胀节	1	BOUGHT-IN 外购件	110	110	
4		CUSHION Ø1060XØ900X2 垫Ø1060XØ900X2	3	460#HEAT RESISTANT RUBBER SLAB	0.5	1.5	
3		WASHER 16 垫圈16	136	65Mn	0.008	1.088	
2		NUT M16 螺母M16	136	8 CLASS	0.029	3.944	
1		BOLT M16X80 螺栓M16X80	96	8.8 CLASS	0.15	14.4	
序号	代 号	名 称	数 量	材 料	单件 重 量	总计 (kg)	备 注
							类别
REV.	DATE	DESIGNED BY	CHECKED BY	REVIEWED BY	APPROVED BY	DESCRIPTION	
OWNER	VIETNAM ELECTRICITY THERMAL POWER PROJECT MANAGEMENT BOARD 3						
CONSULTANT	POWER ENGINEERING CONSULTING JOINT STOCK COMPANY 2						
CONTRACTOR	DONGFANG ELECTRIC CORPORATION LIMITED						
SUBCONTRACTOR	NORTHERN HEAVY INDUSTRIES GROUP CO.LTD						
DEC REF. No.	DUYEN HAI 1/NHI/MGS4766/DZMS0021.01.11						
MANU REF. No.	MGS4766/DZMS0021.01.11						
PROJECT : DUYEN HAI 1 THERMAL POWER PLANT PROJECT				CONTRACT NO. : DH1-30032010			
PULVERIZED COAL CONVEYING PIPELINE I 输粉管道 I							
DESIGNED BY :		张昭军	CHECKED BY :		刘荷	SCALE : 1:20	
REVIEWED BY :		张友				DATE : 2011.11.11	
APPROVED BY :		张友				SUBMITTED FOR: FOR INFORMATION	
STATUS: DETAILED DESIGN		DRAWING NO. : DZMS0015.05.00					REV. 00