



LEGEND

SINGLE A.D.



SOOT BLOWER HOLE



TEMP.&PRESS. MEASURE HOLE



SOOT BLOWER



TEST HOLE



NOX MEASURE HOLE



PRESS. MEASURE HOLE



PRESS.TEST HOLE



技术设计资料

越南沿海一期工程
2x622MW空冷屏炉型火电机组脱硝专用

会签栏:

非承压件设计室	李亚
预热器设计室	李亚
系统与控制设计室	李亚
环保化学室	王彦宾

NOTES

- THIS DWG SHOWS SCR DeNOx of DUYEN HAI 1 POWER PLANT 2x622MW UNIT
- THIS DENOX PLANT ADOPT SELECTIVE CATALYTIC REDUCTION(SCR) TECHNOLOGY .
- THERE ARE 2 SCR REACTORS PER ONE BOILER.

REV.	DATE	DESIGNED BY	CHECKED BY	REVIEWED BY	APPROVED BY	DESCRIPTION		
OWNER		VIETNAM ELECTRICITY THERMAL PROJECT MANAGEMENT BOARD NO.3						
CONSULTANT		POWER ENGINEERING CONSULTING JOINT STOCK COMPANY 2						
CONTRACTOR		DONGFANG ELECTRIC CORPORATION LIMITED						
MANUFACTURER		东方电气集团东方锅炉股份有限公司 DONGFANG BOILER GROUP CO., LTD						
EVN REF. No.								
DEC REF. No.		DH1_DDBSE3_SB_21DN-0.1						
PROJECT :				CONTRACT NO. :				
DUYEN HAI 1 THERMAL POWER PLANT PROJECT				DH1-30032010				
设计 DES.	李亚 李亚 李亚 Zhen Xiao Mo 李亚 李亚 李亚 20100909	标检 STD.	SCR脱硝装置总布置图 GENERAL DRAWING OF SCR		图 号 DRAWING NO.	21DN-0.1		
校对 CK.	李亚 李亚 李亚 Xiao Mo 李亚 李亚 李亚 20100909	工艺 TECH.			比 例 SCALE	1:150	重量 WT.	kg
审核 AUD.	李亚 李亚 李亚 Li Xiao Mo 李亚 李亚 李亚 20100909	批准 APPR.			版本号 REV.	A	第 6 页 SHEET 6	共 1 页 OF 1
审定 VER.		日期 DATE	WORK NO: W272125(UNIT#1) W272126(UNIT#2)		UNITS	mm	4	A4