






130/5-5-5A
SL NO: 168158 /12











1S1-1S2,130/5A,30VA,CL:0.5

2S1-2S2,130/5A,30VA,CL:5P20

3S1-3S2,130/5A,CL:PS



22KV CURRENT TRANSFORMER

RATIO:130/5-5A CLASS:0.5/5P20/PS

BURDEN:30/30VA/- ISF < =5

For Class PS:VK => 135V,Im@VK/2 < =55mA,RCT < =0.6 Ohms

STC:16KA/3.0SEC

ILV:24/50/125KVp

SERIAL.NO/YEAR:168158/12

REF STD IEC:60044-1 1 PHASE FREQ:50/60Hz

MED:KALPA ELECTRICAL PVT.LTD.,BANGALORE-10,INDIA

CT Secondary Terminals
should not kept Open

TI4T1