



1S1-1S2,30/5A,10VA,CL:0.5  
2S1-2S2,30/5A,10VA,CL:5P20

**Kalpa** **22KV CURRENT TRANSFORMER**  
RATIO:30/5 – 5A CLASS:0.5/5P20  
BURDEN:10/10VA ISF < = 20  
STC:16KA/3.0SEC  
ILV:24/50/125KVp  
1 PHASE FREQ:50/60Hz  
SERIAL.NO/YEAR: 168152/12  
REF STD IEC:60044 – 1  
MED:KALPA ELEKTRIKAL PVT.LTD.,BANGALORE – 10,INDIA

CT Secondary Terminals  
should not kept Open


14TD41

C













30/5-5A  
SL.NO: 168152 / 12





