



GHI CHÚ:

——> Điểm đóng lưới hiện hữu

——> Điểm đóng lưới sau khi tạo

Sst	Khu vực trạm	Công suất	Idm	Imax	% tải	Imax sau khi XDM	% tải sau khi XDM
3	PHU LOC 5	1x560	812	719	89	540	67%
	PHU LOC 5/3	3x100	435	326	75	270	62%
	PHU LOC 5/1 (trạm mới)	1x400	580		236	41%	

